



PORTABLE APPLIANCE TESTING CERTIFICATE

Client *Boing Bouncy Castles*
Address *Unit 19, Burrows Lea Farm, Hook Lane, Shere. GU5 9QQ*

No. Tests 109
No. of Items Failed 0
No. of Microwaves Tested 0

Repairs
No. of Fuses Changed 0
No. of Plug Tops Changed 1
No. of Reterminations 1

Date Completed 14th November 2022
Test Engineer J Anderson
Tester Serial No. 31P-0428

Engineers Signature

Anderson Compliance Testing
7 St Johns Street
Godalming
Surrey
GU7 3EH
Tel: 07828 233519
www.andersoncompliancetesting.co.uk

SCHEDULE OF RESULTS

APPLIANCE NUMBER	DESCRIPTION OF APPLIANCE	LOCATION OF APPLIANCE	C1/ C2	FREQ	VISUAL	EARTH BOND (Ω)	INS. (M Ω)	STATUS	FUSE	MW	F	PT	RET	GENERAL COMMENTS
50953	16A LEAD	N/A	1	12	OK	0.07	>19.99	PASS	-					
50954	16A LEAD	N/A	1	12	OK	0.18	>19.99	PASS	-					
50955	16A LEAD	N/A	1	12	OK	0.15	>19.99	PASS	-					
50956	16A LEAD	N/A	1	12	OK	0.27	>19.99	PASS	-					
50957	16A LEAD	N/A	1	12	OK	0.09	>19.99	PASS	-					
50958	16A LEAD	N/A	1	12	OK	0.16	>19.99	PASS	-					
50959	16A LEAD	N/A	1	12	OK	0.23	>19.99	PASS	-					
50960	16A LEAD	N/A	1	12	OK	0.25	>19.99	PASS	-					
50961	16A LEAD	N/A	1	12	OK	0.08	>19.99	PASS	-					
50962	16A LEAD	N/A	1	12	OK	0.17	>19.99	PASS	-					
50963	16A LEAD	N/A	1	12	OK	0.29	>19.99	PASS	-					
50964	16A LEAD	N/A	1	12	OK	0.28	>19.99	PASS	-					
50965	16A LEAD	N/A	1	12	OK	0.25	>19.99	PASS	-					
50966	16A LEAD	N/A	1	12	OK	0.27	>19.99	PASS	-					
50967	16A LEAD	N/A	1	12	OK	0.28	>19.99	PASS	-					
50968	16A LEAD	N/A	1	12	OK	0.30	>19.99	PASS	-					
50969	16A LEAD	N/A	1	12	OK	0.29	>19.99	PASS	-					
50970	16A LEAD	N/A	1	12	OK	0.20	>19.99	PASS	-					
50971	16A LEAD	N/A	1	12	OK	0.14	>19.99	PASS	-				1	REPAIRED DAMAGED CABLE
50972	16A LEAD	N/A	1	12	OK	0.28	>19.99	PASS	-					
50973	16A LEAD	N/A	1	12	OK	0.29	>19.99	PASS	-					
50974	16A LEAD	N/A	1	12	OK	0.28	>19.99	PASS	-					
50975	16A LEAD	N/A	1	12	OK	0.27	>19.99	PASS	-					
50976	16A LEAD	N/A	1	12	OK	0.45	>19.99	PASS	-					
50977	16A LEAD	N/A	1	12	OK	0.26	>19.99	PASS	-					

SCHEDULE OF RESULTS

APPLIANCE NUMBER	DESCRIPTION OF APPLIANCE	LOCATION OF APPLIANCE	C1/ C2	FREQ	VISUAL	EARTH BOND (Ω)	INS. (M Ω)	STATUS	FUSE	MW	F	PT	RET	GENERAL COMMENTS
50978	16A LEAD	N/A	1	12	OK	0.36	>19.99	PASS	-					
50979	16A LEAD	N/A	1	12	OK	0.35	>19.99	PASS	-					
50980	16A LEAD	N/A	1	12	OK	0.26	>19.99	PASS	-					
50981	16A LEAD	N/A	1	12	OK	0.32	>19.99	PASS	-					
50982	16A LEAD	N/A	1	12	OK	0.32	>19.99	PASS	-					
50983	16A LEAD	N/A	1	12	OK	0.32	>19.99	PASS	-					
50984	16A LEAD	N/A	1	12	OK	0.26	>19.99	PASS	-					
50985	16A LEAD	N/A	1	12	OK	0.28	>19.99	PASS	-					
50986	16A LEAD	N/A	1	12	OK	0.28	>19.99	PASS	-					
50987	16A LEAD	N/A	1	12	OK	0.15	>19.99	PASS	-					
50988	16A LEAD	N/A	1	12	OK	0.36	>19.99	PASS	-					
50989	16A LEAD	N/A	1	12	OK	0.40	>19.99	PASS	-					
50990	16A LEAD	N/A	1	12	OK	0.29	>19.99	PASS	-					
50991	16A LEAD	N/A	1	12	OK	0.28	>19.99	PASS	-					
50992	16A LEAD	N/A	1	12	OK	0.28	>19.99	PASS	-					
50993	16A LEAD	N/A	1	12	OK	0.28	>19.99	PASS	-					
50994	13A – 16A LEAD	N/A	1	12	OK	0.04	>19.99	PASS	13					
50995	13A – 16A LEAD	N/A	1	12	OK	0.03	>19.99	PASS	13					
50996	16A – 13A LEAD	N/A	1	12	OK	0.04	>19.99	PASS	-					
50997	BUBBLE MACHINE	N/A	1	12	OK	0.11	3.710	PASS	-					
50998	PORTABLE PA	N/A	1	12	OK	LIM	>19.99	PASS	-					
50999	13A – 16A LEAD	N/A	1	12	OK	0.02	>19.99	PASS	13					
51000	16A – 13A LEAD	N/A	1	12	OK	0.02	>19.99	PASS	-					
51001	16A – 4 WAY LEAD	N/A	1	12	OK	0.04	>19.99	PASS	-					
51002	13A – 16A LEAD	N/A	1	12	OK	0.02	>19.99	PASS	13					

SCHEDULE OF RESULTS

APPLIANCE NUMBER	DESCRIPTION OF APPLIANCE	LOCATION OF APPLIANCE	C1/ C2	FREQ	VISUAL	EARTH BOND (Ω)	INS. (M Ω)	STATUS	FUSE	MW	F	PT	RET	GENERAL COMMENTS
51003	PORTABLE PA	N/A	2	12	OK	-	>19.99	PASS	-					
51004	POWER LEAD	N/A	2	12	OK	-	>19.99	PASS	3					
51005	DISCO LIGHT	N/A	2	12	OK	-	>19.99	PASS	3					
51006	DISCO LIGHT	N/A	2	12	OK	-	>19.99	PASS	3					
51007	13A – 16A LEAD	N/A	1	12	OK	0.02	>19.99	PASS	13					
51008	16A BLOWER	N/A	1	12	OK	0.10	>19.99	PASS	-					
51009	13A – 16A LEAD	N/A	1	12	OK	0.02	>19.99	PASS	13					
51010	16A BLOWER	N/A	1	12	OK	0.08	>19.99	PASS	-					
51011	13A – 16A LEAD	N/A	1	12	OK	0.02	>19.99	PASS	13					
51012	16A BLOWER	N/A	1	12	OK	0.08	>19.99	PASS	-					
51013	16A BLOWER	N/A	1	12	OK	0.07	>19.99	PASS	-					SWITCH BYPASSED
51014	13A – 16A LEAD	N/A	1	12	OK	0.02	>19.99	PASS	13					
51015	16A BLOWER	N/A	1	12	OK	0.08	>19.99	PASS	-					
51016	13A – 16A LEAD	N/A	1	12	OK	0.02	>19.99	PASS	13					
51017	16A BLOWER	N/A	1	12	OK	0.09	>19.99	PASS	-					
51018	13A – 16A LEAD	N/A	1	12	OK	0.02	>19.99	PASS	13					
51019	16A BLOWER	N/A	1	12	OK	0.09	>19.99	PASS	-					
51020	13A – 16A LEAD	N/A	1	12	OK	0.02	>19.99	PASS	13					
51021	16A BLOWER	N/A	1	12	OK	0.10	>19.99	PASS	-					
51022	13A – 16A LEAD	N/A	1	12	OK	0.02	>19.99	PASS	13					
51023	16A BLOWER	N/A	1	12	OK	0.08	>19.99	PASS	-					
51024	13A – 16A LEAD	N/A	1	12	OK	0.02	>19.99	PASS	13					
51025	16A BLOWER	N/A	1	12	OK	0.09	>19.99	PASS	-					
51026	13A – 16A LEAD	N/A	1	12	OK	0.01	>19.99	PASS	13					
51027	16A BLOWER	N/A	1	12	OK	0.06	>19.99	PASS	-					

SCHEDULE OF RESULTS

APPLIANCE NUMBER	DESCRIPTION OF APPLIANCE	LOCATION OF APPLIANCE	C1/ C2	FREQ	VISUAL	EARTH BOND (Ω)	INS. (M Ω)	STATUS	FUSE	MW	F	PT	RET	GENERAL COMMENTS
51028	13A – 16A LEAD	N/A	1	12	OK	0.04	>19.99	PASS	13					
51029	16A BLOWER	N/A	1	12	OK	0.12	>19.99	PASS	-					
51030	13A – 16A LEAD	N/A	1	12	OK	0.02	>19.99	PASS	13					
51031	16A BLOWER	N/A	1	12	OK	0.10	>19.99	PASS	-					
51032	13A – 16A LEAD	N/A	1	12	OK	0.02	>19.99	PASS	13					
51033	16A BLOWER	N/A	1	12	OK	0.08	>19.99	PASS	-					
51034	13A – 16A LEAD	N/A	1	12	OK	0.02	>19.99	PASS	13					
51035	16A BLOWER	N/A	1	12	OK	0.12	>19.99	PASS	-					
51036	13A – 16A LEAD	N/A	1	12	OK	0.02	>19.99	PASS	13					
51037	16A BLOWER	N/A	1	12	OK	0.15	>19.99	PASS	-					
51038	13A – 16A LEAD	N/A	1	12	OK	0.02	>19.99	PASS	13					
51039	16A BLOWER	N/A	1	12	OK	0.10	>19.99	PASS	-					
51040	13A – 16A LEAD	N/A	1	12	OK	0.02	>19.99	PASS	13					
51041	16A BLOWER	N/A	1	12	OK	0.09	>19.99	PASS	-					
51042	13A – 16A LEAD	N/A	1	12	OK	0.02	>19.99	PASS	13					
51043	16A BLOWER	N/A	1	12	OK	0.09	>19.99	PASS	-					
51044	13A – 16A LEAD	N/A	1	12	OK	0.02	>19.99	PASS	13					
51045	16A BLOWER	N/A	1	12	OK	0.08	>19.99	PASS	-					
51046	13A – 16A LEAD	N/A	1	12	OK	0.02	>19.99	PASS	13					
51047	16A BLOWER	N/A	1	12	OK	0.11	>19.99	PASS	-					
51048	13A – 16A LEAD	N/A	1	12	OK	0.02	>19.99	PASS	13					
51049	16A BLOWER	N/A	1	12	OK	0.12	>19.99	PASS	-					
51050	16A BLOWER	N/A	1	12	OK	0.07	>19.99	PASS	-					
51051	13A – 16A LEAD	N/A	1	12	OK	0.04	>19.99	PASS	13					
51052	16A BLOWER	N/A	1	12	OK	0.12	>19.99	PASS	-					HEATSHRINK REPAIR

SCHEDULE OF RESULTS

APPLIANCE NUMBER	DESCRIPTION OF APPLIANCE	LOCATION OF APPLIANCE	C1/ C2	FREQ	VISUAL	EARTH BOND (Ω)	INS. (M Ω)	STATUS	FUSE	MW	F	PT	RET	GENERAL COMMENTS				
51053	13A – 16A LEAD	N/A	1	12	OK	0.03	>19.99	PASS	13									
51054	16A BLOWER	N/A	1	12	OK	0.08	>19.99	PASS	-									
51055	16A BLOWER	N/A	1	12	OK	0.05	>19.99	PASS	-									
51056	13A – 16A LEAD	N/A	1	12	OK	0.02	>19.99	PASS	13									
51057	16A BLOWER	N/A	1	12	OK	0.05	>19.99	PASS	-									
51058	16A BLOWER	N/A	1	12	OK	0.08	>19.99	PASS	-									
51059	16A BLOWER	N/A	1	12	OK	0.06	>19.99	PASS	-									
51060	16A SPLITTER	N/A	1	12	OK	0.04	>19.99	PASS	-									
51061	16A LEAD	N/A	1	12	OK	0.28	>19.99	PASS	-			1		SUPPLIED & FITTED 16A PLUG				
TOTAL NUMBER OF ITEMS									109		TOTAL REPAIRS			0	0	1	1	