



PORTABLE APPLIANCE TESTING CERTIFICATE

Client *Boing Bouncy Castles*
Address *Burrows Lea Farm, Hook Lane, Shere. GU5 9QQ*

No. Tests *107*
No. of Items Failed *1*
No. of Microwaves Tested *0*

Repairs
No. of Fuses Changed *0*
No. of Plug Tops Changed *0*
No. of Reterminations *0*

Date Completed *6th November 2024*
Test Engineer *J Anderson*
Tester Serial No. *31P-0428*

Engineers Signature

Anderson Compliance Testing
7 St Johns Street
Godalming
Surrey
GU7 3EH
Tel: 07828 233519
www.andersoncompliancetesting.co.uk

SCHEDULE OF RESULTS

APPLIANCE NUMBER	DESCRIPTION OF APPLIANCE	LOCATION OF APPLIANCE	C1/ C2	FREQ	VISUAL	EARTH BOND (Ω)	INS. ($M\Omega$)	STATUS	FUSE	MW	F	PT	RET	GENERAL COMMENTS
106176	16A LEAD	N/A	1	12	OK	0.34	>19.99	PASS	-					
106177	16A LEAD	N/A	1	12	OK	0.33	>19.99	PASS	-					
106178	16A LEAD	N/A	1	12	OK	0.35	>19.99	PASS	-					
106179	16A LEAD	N/A	1	12	OK	0.31	>19.99	PASS	-					
106180	16A LEAD	N/A	1	12	OK	0.29	>19.99	PASS	-					
106181	16A LEAD	N/A	1	12	OK	0.29	>19.99	PASS	-					
106182	16A LEAD	N/A	1	12	OK	0.42	>19.99	PASS	-					
106183	16A LEAD	N/A	1	12	OK	0.31	>19.99	PASS	-					
106184	16A LEAD	N/A	1	12	OK	0.30	>19.99	PASS	-					
106185	16A LEAD	N/A	1	12	OK	0.32	>19.99	PASS	-					
106186	16A LEAD	N/A	1	12	OK	0.31	>19.99	PASS	-					
106187	16A LEAD	N/A	1	12	OK	0.29	>19.99	PASS	-					
106188	16A LEAD	N/A	1	12	OK	0.33	>19.99	PASS	-					
106189	16A LEAD	N/A	1	12	OK	0.05	>19.99	PASS	-					
106190	16A LEAD	N/A	1	12	OK	0.15	>19.99	PASS	-					
106191	16A LEAD	N/A	1	12	OK	0.12	>19.99	PASS	-					
106192	16A LEAD	N/A	1	12	OK	0.15	>19.99	PASS	-					
106193	16A LEAD	N/A	1	12	OK	0.18	>19.99	PASS	-					
106194	16A LEAD	N/A	1	12	OK	0.30	>19.99	PASS	-					
106195	16A LEAD	N/A	1	12	OK	0.15	>19.99	PASS	-					
106196	16A LEAD	N/A	1	12	OK	0.30	>19.99	PASS	-					
106197	16A LEAD	N/A	1	12	OK	0.29	>19.99	PASS	-					
106198	16A LEAD	N/A	1	12	OK	0.16	>19.99	PASS	-					
106199	16A LEAD	N/A	1	12	OK	0.30	>19.99	PASS	-					
106200	16A LEAD	N/A	1	12	OK	0.09	>19.99	PASS	-					

SCHEDULE OF RESULTS

APPLIANCE NUMBER	DESCRIPTION OF APPLIANCE	LOCATION OF APPLIANCE	C1/ C2	FREQ	VISUAL	EARTH BOND (Ω)	INS. ($M\Omega$)	STATUS	FUSE	MW	F	PT	RET	GENERAL COMMENTS
106201	16A LEAD	N/A	1	12	OK	0.20	>19.99	PASS	-					
106202	16A LEAD	N/A	1	12	OK	0.20	>19.99	PASS	-					
106203	16A LEAD	N/A	1	12	OK	0.20	>19.99	PASS	-					
106204	16A LEAD	N/A	1	12	OK	0.20	>19.99	PASS	-					
106205	16A LEAD	N/A	1	12	OK	0.32	>19.99	PASS	-					
106206	16A LEAD	N/A	1	12	OK	0.31	>19.99	PASS	-					
106207	16A LEAD	N/A	1	12	OK	0.29	>19.99	PASS	-					
106208	16A LEAD	N/A	1	12	OK	0.28	>19.99	PASS	-					
106209	16A LEAD	N/A	1	12	OK	0.26	>19.99	PASS	-					
106210	16A LEAD	N/A	1	12	OK	0.21	>19.99	PASS	-					
106211	16A LEAD	N/A	1	12	OK	0.29	>19.99	PASS	-					
106212	16A LEAD	N/A	1	12	OK	0.30	>19.99	PASS	-					
106213	16A LEAD	N/A	1	12	OK	0.41	>19.99	PASS	-					
106214	16A LEAD	N/A	1	12	OK	0.31	>19.99	PASS	-					
106215	16A LEAD	N/A	1	12	OK	0.29	>19.99	PASS	-					
106216	16A LEAD	N/A	1	12	OK	0.28	>19.99	PASS	-					
106217	16A LEAD	N/A	1	12	OK	0.27	>19.99	PASS	-					
106218	16A LEAD	N/A	1	12	OK	0.28	>19.99	PASS	-					
106219	16A LEAD	N/A	1	12	OK	0.28	>19.99	PASS	-					
106220	16A LEAD	N/A	1	12	OK	0.28	>19.99	PASS	-					
106221	ACTIVE SPEAKER	N/A	1	12	OK	LIM	>19.99	PASS	-					
106222	POWER LEAD	N/A	1	12	OK	0.17	>19.99	PASS	5					
106223	16A – 13A EXTENSION	N/A	1	12	OK	0.03	>19.99	PASS	-					
106224	13A – 16A LEAD	N/A	1	12	OK	0.03	>19.99	PASS	13					
106225	ACTIVE SPEAKER	N/A	2	12	OK	-	>19.99	PASS	-					

SCHEDULE OF RESULTS

APPLIANCE NUMBER	DESCRIPTION OF APPLIANCE	LOCATION OF APPLIANCE	C1/ C2	FREQ	VISUAL	EARTH BOND (Ω)	INS. ($M\Omega$)	STATUS	FUSE	MW	F	PT	RET	GENERAL COMMENTS
106226	16A BLOWER	N/A	1	12	OK	0.10	>19.99	PASS	-					
106227	13A – 16A LEAD	N/A	1	12	OK	0.05	>19.99	PASS	13					
106228	16A BLOWER	N/A	1	12	OK	0.09	>19.99	PASS	-					
106229	13A – 16A LEAD	N/A	1	12	OK	0.05	>19.99	PASS	13					
106230	16A BLOWER	N/A	1	12	OK	0.05	>19.99	PASS	-					
106231	16A BLOWER	N/A	1	12	OK	0.03	>19.99	PASS	-					
106232	13A – 16A LEAD	N/A	1	12	OK	0.04	>19.99	PASS	13					
106233	16A BLOWER	N/A	1	12	OK	0.13	>19.99	PASS	-					
106234	16A BLOWER	N/A	1	12	OK	0.12	>19.99	PASS	-					
106235	16A BLOWER	N/A	1	12	OK	0.09	>19.99	PASS	-					
106236	16A BLOWER	N/A	1	12	OK	0.05	>19.99	PASS	-					
106237	13A – 16A LEAD	N/A	1	12	OK	0.03	>19.99	PASS	13					
106238	16A BLOWER	N/A	1	12	OK	0.10	>19.99	PASS	-					
106239	13A – 16A LEAD	N/A	1	12	OK	-	0.030	FAIL	-					SEE FAIL SHEET
106240	16A BLOWER	N/A	1	12	OK	0.15	>19.99	PASS	-					
106241	13A – 16A LEAD	N/A	1	12	OK	0.05	>19.99	PASS	13					
106242	16A BLOWER	N/A	1	12	OK	0.09	>19.99	PASS	-					
106243	13A – 16A LEAD	N/A	1	12	OK	0.04	>19.99	PASS	13					
106244	16A BLOWER	N/A	1	12	OK	0.10	>19.99	PASS	-					
106245	13A – 16A LEAD	N/A	1	12	OK	0.05	>19.99	PASS	13					
106246	16A BLOWER	N/A	1	12	OK	0.10	>19.99	PASS	-					
106247	13A – 16A LEAD	N/A	1	12	OK	0.04	>19.99	PASS	13					
106248	16A BLOWER	N/A	1	12	OK	0.10	>19.99	PASS	-					
106249	13A – 16A LEAD	N/A	1	12	OK	0.04	>19.99	PASS	13					
106250	16A BLOWER	N/A	1	12	OK	0.12	>19.99	PASS	-					

SCHEDULE OF RESULTS

APPLIANCE NUMBER	DESCRIPTION OF APPLIANCE	LOCATION OF APPLIANCE	C1/ C2	FREQ	VISUAL	EARTH BOND (Ω)	INS. ($M\Omega$)	STATUS	FUSE	MW	F	PT	RET	GENERAL COMMENTS
106251	13A – 16A LEAD	N/A	1	12	OK	0.05	>19.99	PASS	13					
106252	16A BLOWER	N/A	1	12	OK	0.06	>19.99	PASS	-					
106253	13A – 16A LEAD	N/A	1	12	OK	0.11	>19.99	PASS	13					
106254	16A BLOWER	N/A	1	12	OK	0.14	>19.99	PASS	-					
106255	13A – 16A LEAD	N/A	1	12	OK	0.07	>19.99	PASS	13					
106256	16A BLOWER	N/A	1	12	OK	0.10	>19.99	PASS	-					
106257	16A BLOWER	N/A	1	12	OK	0.15	>19.99	PASS	-					
106258	13A – 16A LEAD	N/A	1	12	OK	0.05	>19.99	PASS	13					
106259	16A BLOWER	N/A	1	12	OK	0.08	>19.99	PASS	-					
106260	13A – 16A LEAD	N/A	1	12	OK	0.05	>19.99	PASS	13					
106261	16A BLOWER	N/A	1	12	OK	0.13	>19.99	PASS	-					
106262	13A – 16A LEAD	N/A	1	12	OK	0.06	>19.99	PASS	13					
106263	16A BLOWER	N/A	1	12	OK	0.08	>19.99	PASS	-					
106264	13A – 16A LEAD	N/A	1	12	OK	0.04	>19.99	PASS	13					
106265	16A BLOWER	N/A	1	12	OK	0.12	>19.99	PASS	-					
106266	16A SPLITTER	N/A	1	12	OK	0.02	>19.99	PASS	-					
106267	16A BLOWER	N/A	1	12	OK	0.09	>19.99	PASS	-					
106268	13A – 16A LEAD	N/A	1	12	OK	0.05	>19.99	PASS	13					
106269	16A BLOWER	N/A	1	12	OK	0.07	>19.99	PASS	-					
106270	16A BLOWER	N/A	1	12	OK	0.15	>19.99	PASS	-					
106271	16A BLOWER	N/A	1	12	OK	0.15	>19.99	PASS	-					SWITCH BYPASSED
106272	16A BLOWER	N/A	1	12	OK	0.07	>19.99	PASS	-					
106273	16A BLOWER	N/A	1	12	OK	0.08	>19.99	PASS	-					
106274	16A BLOWER	N/A	1	12	OK	0.06	>19.99	PASS	-					
106275	16A BLOWER	N/A	1	12	OK	0.07	>19.99	PASS	-					

SCHEDULE OF RESULTS

APPLIANCE NUMBER	DESCRIPTION OF APPLIANCE	LOCATION OF APPLIANCE	C1/ C2	FREQ	VISUAL	EARTH BOND (Ω)	INS. ($M\Omega$)	STATUS	FUSE	MW	F	PT	RET	GENERAL COMMENTS	
106276	13A – 16A LEAD	N/A	1	12	OK	0.04	>19.99	PASS	13						
106277	BUBBLE MACHINE PSU	N/A	2	12	OK	-	>19.99	PASS	-						
106278	13A – 16A LEAD	N/A	1	12	OK	0.05	>19.99	PASS	13						
106279	16A – 13A EXTENSION	N/A	1	12	OK	0.04	>19.99	PASS	-						
106280	BUBBLE MACHINE PSU	N/A	2	12	OK	-	>19.99	PASS	-						
106281	13A – 16A LEAD	N/A	1	12	OK	0.04	>19.99	PASS	13						
106282	16A – 13A EXTENSION	N/A	1	12	OK	0.03	>19.99	PASS	-						
TOTAL NUMBER OF ITEMS		107							TOTAL REPAIRS		0	0	0	0	FEA – FIXED ELECTRICAL APPLIANCE NAPT – NO ACCESS TO PLUG TOP

PORTABLE APPLIANCE TESTING - FAILED ITEMS & OBSERVATIONS

Site Name: Boing Bouncy Castles

Item Description	Location	Appliance No.	Reason for Failure
13A – 16A Lead	N/A	106239	Low Insulation Resistance
General Observations/Comments:			

Test Engineer: J Anderson
Date: 6th November 2024

*Anderson Compliance Testing
7 St Johns Street
Godalming
Surrey
GU7 3EH*

Tel: 07828 233519